

Addendum 2

1. Can the bid due date be extended a week?
 - A. No, It's going to be a tight construction deadline so we need to get going ASAP
2. For the Lipscomb tower, is the assembly hardware available for assembling the sections together?
 - A. No, they will need to be provided.
3. SOW says we are to supply guy wires, do we also provide the anchors?
 - A. Yes, plan on providing everything except the tower sections.
4. Do we need to supply a safety climb device and lightning rod?
 - A. Yes
5. Do you have any details of the tower sections?
 - A. It is a 55g
6. Can we submit a tower manufacturer design/pricing that is not the approved 3 as listed on the bid?
 - A. Yes, you can bid out any tower manufacturer as long as they meet the specifications.